



State of Ohio Environmental P

Southwest Distri

401 E. Fifth St.
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6357
www.epa.ohio.gov

Chris Korleski, Director

December 2, 2009

Village of South Vienna
Attn: Board of Public Affairs
149 Main Street
South Vienna, OH 45369

Re: Village of South Vienna
Clark County
Community Water System
PWS ID: 1204312

Subject: Monthly Operating Report Violation

Dear Board Representative:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of **October 2009**, the Village of South Vienna public water system did send the monthly report to this office. However, the report contained missing data for the plant tap free chlorine residual on the following dates: October 19 – 31, 2009. This is a violation of the rule. The Village of South Vienna public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that future reports are submitted each month.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6085.

Sincerely,

Tya Darden
Division of Drinking and Groundwaters
Public Drinking Water Unit

cc: Dave Bornino, Ohio EPA, DDAGW, CO
Clark County Health Department
Brenda Sweeney, Certified Operator