



State of Ohio Environment

401 East Fifth Street
Dayton, Ohio 45402-2911

Southwest
TELE: (937)285-6357 F.
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 5, 2007

RE: STATELINE AGRI INC.
DARKE COUNTY
COMMUNITY WATER SYSTEM
PWS I.D. 1901012

Stateline Agri Inc.
Wendy Aultman
9159 State Route 118
Ansonia, Ohio 45303

Dear Ms. Aultman:

On December 5, 2007, I spoke with you regarding the monthly operating report (MOR) for October 2007. Because Stateline Agri is a community public water system, you are required to monitor for free or combined chlorine at least once every day that water is available to the public. You are required to monitor daily at each entry point to the distribution system and at a representative point in the distribution system. Based upon my review of the October report, sampling for free or combined chlorine was not conducted at the entry point or in the distribution system on the weekends. You have the option of installing a continuous chlorine meter and recorder on your system if you choose to. I have attached our policy regarding continuous chlorine meters for your assistance.

Per our phone conversation, Stateline Agri will begin monitoring for chlorine daily and report the chlorine monitoring results on the MOR beginning with the December, 2007 MOR and subsequent reports thereafter. Attached is a copy of the operational requirements (OAC 3745-83-01) for your review.

If you have any further questions, please contact me at (937) 285-6085.

Sincerely,

Tya C. Darden
Environmental Specialist II
Division of Drinking and Ground Waters
Public Drinking Water Group

Enclosures

CC: Dave Evans
Darke County Health Department
File

TD/plh