



State of Ohio Environment

401 East Fifth Street  
Dayton, Ohio 45402-2911

Southwest  
TELE: (937)285-6357 F  
www.epa.state.ohio.us

Chris Korleski, Director

October 24, 2008

RE: **STATELINE AGRI INC.  
DARKE COUNTY  
COMMUNITY WATER SYSTEM  
PWS I.D. 1901012**

Stateline Agri Inc.  
Ms. Wendy Aultman  
9159 State Route 118  
Ansonia, Ohio 45303

Dear Ms. Aultman:

Stateline Agri, Inc. is a community public water system and is therefore required to monitor for free or combined chlorine at least once every day that water is available to the public. You are required to monitor daily at each entry point to the distribution system **and** at a representative point in the distribution system. If Stateline Agri, Inc. does not have a sampling tap at the entry point, the entry point sample location should be the first customer's residence. Based upon my review of all of the 2007 and 2008 monthly operating reports, sampling for free or combined chlorine was not conducted at the entry point or first customer. Stateline Agri, Inc. is currently in violation of the operational requirements (OAC 3745-83-01)(G)(1).

For future Monthly Operating Reports (MORs), Stateline Agri, Inc. shall take chlorine residuals at both the entry point and in the distribution system.

If you have any further questions, please contact me at (937) 285 - 6085.

Sincerely,

Tya C. Darden  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Public Drinking Water Group

TCD/rif

Enclosures

cc: Dave Evans  
Darke County Health Department  
File