



State of Ohio Environmental

**Southwest Distr**

401 E. Fifth St.  
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX:  
www.epa.ohio.gov

Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

November 12, 2009

Re: Stateline Agri, Inc.  
Darke County  
Community Water System  
PWS ID: 1901012

**Stateline Agri, Inc.**

Attn: Wendy Aultman  
9159 State Route 118  
Ansonia, OH 45303

**Subject: Monthly Operating Report, Failure to Submit**

Dear Mr. Olsen:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the months of August and September 2009, Stateline Agri, Inc. public water system failed to send the monthly report to this office. This is a violation of the rule. Stateline Agri, Inc. public water system shall provide an explanation in writing to Ohio EPA concerning this matter; and explain what steps will be taken to ensure that future reports are submitted no later than the tenth of the month following the month for which the report was prepared.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6118.

Sincerely,

Gina Hayes  
Division of Drinking and Ground Waters  
Public Drinking Water Unit

cc: Dave Bornino, Ohio EPA, DDAGW, CO  
Darke County Health Department  
File

GH/ca