



State of Ohio Environm

Southwest I

401 E. Fifth St.
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 200-0245
www.epa.state.oh.us

ROD STRUMBAUGH, GOVERNOR
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 27, 2009

Re: Greenlawn Condominiums
Clark County
Community Water System
PWS ID: 1204912

Greenlawn Condominiums
Attn: Martin Shields
3314 Scotsdale Drive
Springfield, OH 45504

Subject: Monthly Operating Report, Failure to Submit

Dear Mr. Shields:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of February 2009, Greenlawn Condominiums public water system failed to send the monthly report to this office. This is a violation of the rule. Greenlawn Condominiums public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that future reports are submitted each month.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6085.

Sincerely

Tya Darden
Division of Drinking and Groundwaters
Public Drinking Water Unit

cc: Dave Evans, Ohio EPA, DDAGW, CO
Clark County Health Department
Greenlawn Condos Owners Association, Springfield, OH 45504
File

TD/ca