

**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Carmen Lubeth, Director

December 1, 2010

Re: Greenlawn Condominiums  
Clark County  
Community Water System  
PWS ID: 1204912

Greenlawn Condominiums  
Attn: Martin Shields  
3314 Scottsdale Drive  
Springfield, OH 45504

Subject: Monthly Operating Report

Dear Mr. Shields:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of OCTOBER 2010, Greenlawn Condominiums public water system did send the monthly report to this office. However, Greenlawn Condominiums is currently not monitoring the chlorine residual for both the plant and the distribution. The current report only shows results for the distribution. As explained during the Sanitary Survey and in subsequent emails to you, the rule states that both the free and total chlorine results shall be recorded for both the plant tap and the distribution. If there is no plant tap, the operator shall take the plant tap sample from the first available location. This is a violation of the rule. Greenlawn Condominiums public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that future reports are submitted each month with the correct data.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6085.

Sincerely,



Tya Darden

Division of Drinking and Groundwaters  
Public Drinking Water Unit

cc: Dave Bornino, Ohio EPA, DDAGW, CO  
Clark County Health Department  
Greenlawn Condos Owners Association, Attn: Jim Yoakem

TD/mab