



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

NOTICE OF VIOLATION – ACTION REQUIRED

June 8, 2009

RE: **Pike County**
Longs Retreat Well 16
Non-Community, Transient
PWS ID: OH6633712

Eric Long
50 Bell Hollow Rd
Latham, OH 45646

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During Second Quarter of 2009 (Monthly)**

Longs Retreat Well 16 is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Post the public notice that was sent to you with the Acute violation letter dated June 3, 2009.
- 3. Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 740-380-5274 .

Sincerely,

Eric Hart
District Engineer

EH/cb

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Pike County Health Department
Information Management Section, DDAGW, CO
District File Copy