



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

May 23, 2012

RE: Tecumseh Court MHP
Clark County
PWS ID #: OH1204512
Community Water System

Mr. Anthony Zimmerman
Tecumseh Court MHP
9420 Bellefontaine Road
New Carlisle, Ohio 45344

Subject: Monthly Operating Report (MOR) Violation

Dear Mr. Zimmerman:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of April 2012, Tecumseh Court MHP public water system sent in a report to this office. However, for April 2, 2012 – April 15, 2012, the results are below the minimum requirement of 0.2 milligrams per liter free chlorine. This is a violation of the rule.

Tecumseh Court MHP public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that future reports are submitted each month.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6085.

Sincerely,

Tya Darden
Environmental Specialist
Division of Drinking and Ground Waters
Public Drinking Water Unit

cc: Dave Evans, Ohio EPA, DDAGW, CO
Michael J. Ullman, Certified Operator
ec: Clark County Health Department

TD\bp