



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

March 22, 2011

RE: **Village of Leesburg**  
**Highland County**  
**Community Water System**  
**PWS ID: 3600712**

Village of Leesburg  
Freddie Snyder, Village Administrator  
575 Fairfield Street  
P.O. Box 311  
Leesburg, OH 45135

**Subject: Monthly Operating Violation, Failure to meet requirement**

To Whom It May Concern:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of **February 2011**, the Village of Leesburg public water system failed to meet the required residual for free or combined chlorine on five different days. This is a violation of the rule. The Village of Leesburg public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain the progress that has been made to ensure that the free or total chlorine residuals are maintained in the distribution system and at the plant tap within 30 days of the date of this letter.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937.285.6118.

Sincerely,

Gina Hayes  
Division of Drinking and Ground Waters  
Public Drinking Water Unit

GH/rb

cc: Dave Bornino, Ohio EPA, DDAGW, CO  
Ernie Stickler, Operator, 5403 Liberty Court, Milford, Ohio 45150