

**Environmental  
Protection Agency**

Gov. Scott Jones, Governor  
Lieke Freese, Lt. Governor  
Dana Burdick, Director

December 22, 2010

Re: Village of Leesburg  
Highland County  
Community Water System  
PWS ID: 3600712

Village of Leesburg  
Freddie Snyder, Village Administrator  
575 Fairfield Street  
P.O. Box 311  
Leesburg, OH 45135

Subject: Monthly Operating Violation, Failure to meet requirement

To Whom It May Concern:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of October 2010, the Village of Leesburg public water system failed to meet the required residual for free or combined chlorine on sixteen different days. This is a violation of the rule. The Village of Leesburg public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain the progress that has been made to ensure that the free or total chlorine residuals are maintained in the distribution system and at the plant tap within 30 days of the date of this letter.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937.285.6118.

Sincerely,



Gina Hayes  
Division of Drinking and Ground Waters  
Public Drinking Water Unit

cc: Dave Bornino, Ohio EPA, DDAGW, CO  
Ernie Stickler, Operator

GH/mab