

**Environmental  
Protection Agency**

Paul Straubinger, Governor  
Lee Fisher, Lt. Governor  
Chris Forester, Director

April 29, 2010

Re: Village of Leesburg  
**Highland County**  
Community Water System  
PWS ID: 3600712

Village of Leesburg  
Freddie Snyder, Village Administrator  
575 Fairfield Street  
P.O. Box 311  
Leesburg, OH 45135

Subject: Monthly Operating Violation, Failure to meet requirement

To Whom It May Concern:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of March 2009, the Village of Leesburg public water system failed to meet the required residual for free or combined chlorine on eight different days. This is a violation of the rule. The Village of Leesburg public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that the free or total chlorine residuals are maintained in the distribution system and at the plant tap.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937.285.6118.

Sincerely,



Gina Hayes  
Division of Drinking and Ground Waters  
Public Drinking Water Unit

CC: Dave Bornino, Ohio EPA, DDAGW, CO  
Ernie Stickler, Operator, 5403 Liberty Court, Milford, Ohio 45150

GH/mab