

**Environmental
Protection Agency**

Tom D'Amico, Governor
Jack F. Fallick, Lt. Governor
Chris F. Johnson, Director

November 22, 2010

**RE: SHELBY COUNTY
THE WAY INTERNATIONAL
COMMUNITY WATER SUPPLY
PWS ID: #7501412**

The Way International
Mr. Robert Green
Chief Facilities Officer
P.O. Box 328
5555 Wierville Road
New Knoxville, Ohio 45871

Dear Mr. Green:

The Way International Water System violated Chapter 3745-83-01 of the Ohio Administrative Code (OAC) when the following operational requirements were not met during the month of September 2010 when:

The water system failed to provide sufficient disinfection treatment of its drinking water for twelve (12) days during the month when the residual disinfectant concentration of the drinking water at representative points throughout the distribution systems was less than least two-tenths milligram per liter free chlorine, or one milligram per liter combined chlorine measured at representative points throughout the distribution system.

The Way International Water System fail to correct its violations, Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me.

Sincerely,



Mariano Haensel, M.S.
937-285-6113 - Phone
937-285-6750 - FAX
mariano.haensel@epa.state.oh.us

MH/ka

cc: Shelby County General Health District
Dave Bornino, Ohio EPA, DDAGW, CO