



State of Ohio Environmental Protection Agency

§

401 E. Fifth St.
Dayton, Ohio 45402

governor
governor
Director

December 21, 2009

Re: **SUNSHINE MOBILE PARK
MIAMI COUNTY
COMMUNITY WATER SYSTEM
PWS ID: #5501412**

Mr. Sumner Saeks
New Growth Advisors
4675 Cornell Road, Suite 195
Cincinnati, Ohio 45241

Subject: Failure to Maintain Minimum Chlorine Residuals

Dear Mr. Saeks:

According to Ohio Administrative Code 3745-83-01 Operational Requirements, each community public water system shall maintain a minimum chlorine residual of at least two-tenths milligram per liter free chlorine, or one milligram per liter combined chlorine measured at representative points throughout the distribution system.

For the month of November 2009, Sunshine Mobile Home Park has failed to maintain the required minimum chlorine residual for the park's distribution system on 2-3, 6, 9 10, 12-17, 19, 23-26 and 30 for the month. This is unacceptable.

In response, all available residuals must be documented on the November, 2009 Monthly Operating Report. The report is to be completed, signed and submitted to this office by December 10, 2009.

Also, a written explanation of why the chlorine residuals were not maintained during those dates, how you resolved the problem, and what you have done to ensure that the chlorine residuals are properly maintained in the future. This written response is to be submitted to this office by January 15, 2010.

Mr. Sumner Saeks
December 21, 2009
Page 2

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6117.

Sincerely,

A handwritten signature in black ink that reads "John McDaniel". The signature is written in a cursive style with a large initial "J" and "M".

John McDaniel
Division of Drinking and Groundwaters
Public Drinking Water Unit

Ohio EPA, DDAGW, CO

David Secor, Ohio EPA, SWDO Enforcement Coordinator

JM/mab