



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

May 14, 2012

Re: **Fairfield County
Hillview Mobile Village
Community Water System
PWS ID NO: 2302712**

Mark Anthony
Owner
Marlin Trace Investments
15111 SR 664 South
Logan, OH 43138

VIOLATIONS: Failure to Maintain & Report Minimum Chlorine Residual Levels

Monthly reports show the Hillview Mobile Village public water system is in violation for failure to maintain and report minimum chlorine residual levels daily.

Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1) requires maintaining a minimum chlorine residual of at least 0.2 mg/L free chlorine or 1.0 mg/L combined chlorine measured daily at representative points throughout the distribution system.

During the months of February, March and April 2012, distribution levels of free chlorine were reported to be less than 0.2 mg/L for a total of 24 days. On three of those days, the level was reported as '0'. This means that on those three days, chlorine disinfectant was absent from the system altogether.

Ohio Administrative Code (OAC) Rule 3745-83-01(F)(2)(a) requires daily monitoring for free or combined chlorine at the plant tap. This is in addition to daily distribution system monitoring. Chlorine residual levels failed to be reported during the entire months of February, March and April, 2012.

Please respond in writing, within ten days of the date of this letter, with an explanation of the specific circumstances that resulted in level of chlorine below the minimum required to be maintained and why chlorine residual levels were not measured at all at the plant tap. Include the steps that will be taken to prevent each of these violations from reoccurring in the future.

Mark Anthony
Marlin Trace Investments
Page -2-

If you wish to discuss these issues, I can be reached at 614/728-3864 or by e-mail at Carolyn.oneal@epa.state.oh.us.

Sincerely,

A handwritten signature in black ink that reads "Carolyn O'Neal". The signature is written in a cursive, flowing style.

Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

c: Jim Bennett, Operator of Record
Fairfield County Health Department
ec: DDAGW/CDO
eDoc