Environmental
OH3700312 Valleyview Estates MHP 1/24/2011
DDGWOH3700312547413 6

January 24, 2011

RE: Hocking County
Valleyview Estates MHP
Community
3700312

Valleyview Estates MHP
Attn: Mark Anthony
15111 SR 664 South
Logan, OH 43138

Subject: Monthly Reporting

We have reviewed your Plant Distribution Monthly Operation Reports covering the time period of December 2010 and have noted the following deficiencies:

- Chlorine levels were not analyzed at the plant tap and distribution system as required on 23 days over the month of December.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office / DDAGW
cc: Hocking Health Department
cc: Jamie Wilkins, SEDO

Southeast District Office
2195 Front Street
Logan, OH 43138-8637

740 | 385 8501
740 | 385 6490 (fax)
www.epa.ohio.gov