


OH3700312

Valleyview Estates MHP

7/25/2011



July 25, 2011

RE: **Hocking County**
Valleyview Estates MHP
Community
3700312

Valleyview Estates MHP
Attn: Mark Anthony
15111 SR 664 South
Logan, OH 43138

Subject: Monthly Reporting Violations

We have reviewed your Plant Distribution Monthly Operation Reports covering the time period of June 2011 and have noted the following violations:

- Chlorine levels were not analyzed at the plant tap and distribution system as required on 16 days over the month.

Please take prompt action to correct these reporting violations in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

A handwritten signature in black ink that reads "Randy R. Smith".

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office / DDAGW
cc: Hocking Health Department
cc: **Jamie Wilkins, SEDO**