



June 15, 2011

RE: **Hocking County**
Valleyview Estates MHP
Community
3700312

Valleyview Estates MHP
Attn: Mark Anthony
15111 SR 664 South
Logan, OH 43138

Subject: Monthly Reporting Violations

We have reviewed your Plant Distribution Monthly Operation Reports covering the time period of May 2011 and have noted the following violations:

- Chlorine levels were not analyzed at the plant tap and distribution system as required on 20 days over the month.
- One sample was below 0.2 mg/l free chlorine.

Please take prompt action to correct these reporting violations in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

A handwritten signature in black ink that reads "Randy R. Smith".

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office / DDAGW
cc: Hocking Health Department
cc: **Jamie Wilkins, SEDO**