



2195 Front Street  
Logan, Ohio 43138

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 2, 2007

Re: **HOCKING COUNTY**  
**VALLEYVIEW ESTATES MHP**  
**PWS ID 3700312**

Valleyview Estates MHP  
Mark Anthony  
15111 SR 664 South  
Logan OH 43138

**Subject: Minor Violation of the Consumer Confidence Report Requirements**

Ohio EPA received the Valleyview Estate MHP's Consumer Confidence Report (CCR) for 2006. The CCR was reviewed for the required content. Based on our review, the Valleyview Estates MHP water system is in violation of rules 3745-96-01 through 04 of the Ohio Administrative Code for failure to comply with the CCR requirements. The following violations were noted:

- the data for the Table of Detected Contaminants was not presented in the required table format, and did not include the MCL, MCLG, range, violations, level, source and sample year for each detected contaminant;
- the Table of Detected Contaminants did not include the residual disinfectant information as required (the chlorine results at the time of bacteriological sample collection);
- the source water susceptibility language was not included as required.

Be sure to correct the violations as appropriate in your next CCR. The next report for calendar year 2007 must be sent to your customers no later than June 30, 2008. A copy of the CCR along with a Certification Form must be submitted to this office no later than July 1, 2008.

If you have any questions, please contact me at (740) 380-5274.

Sincerely,

Eric Hart  
Environmental Engineer  
Division of Drinking and Ground Waters

EH/cb

cc: Hocking County Health Department  
cc: **Jamie Hedges, SEDO**