

TELE: (740) 385-8501 FAX: (740) 385-0450
www.epa.state.oh.us2195 Front Street
Logan, Ohio 43138Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 2, 2007

Re: **HOCKING COUNTY**
SCENIC HILL ESTATES MHP
PWS ID 3700912Scenic Hills Estates MHP
Jo Fuller
14595 Bradford Dr
Logan OH 43138**Subject: Minor Violation of the Consumer Confidence Report Requirements**

Ohio EPA received the Scenic Hills Estates MHP's Consumer Confidence Report (CCR) for 2006. The CCR was reviewed for the required content. Based on our review, the Scenic Hills Estates MHP water system is in violation of rules 3745-96-01 through 04 of the Ohio Administrative Code for failure to comply with the CCR requirements. The following violations were noted:

- the Table of Detected Contaminants did not include the data required (level, MCL, MCLG, range, violations, level, source and sample year) for the contaminants barium, radium 228 and haloacetic acids (HAA5) which were detected in your water system;
- the Table of Detected Contaminants did not include the residual disinfectant information as required (the total chlorine results at the time of bacteriological sample collection);
- the required definitions for terms and abbreviations used in the report (MCL, ug/l, etc.) were not included;
- the source water susceptibility language was not included.

Be sure to correct the violations as appropriate in your next CCR. The next report for calendar year 2007 must be sent to your customers no later than June 30, 2008. A copy of the CCR along with a Certification Form must be submitted to this office no later than July 1, 2008.

If you have any questions, please contact me at (740) 380-5274.

Sincerely,

Eric Hart
Environmental Engineer
Division of Drinking and Ground Waters

EH/cb

cc: Hocking County Health Department
cc: **Jamie Hedges, SEDO**