



TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

NOTICE OF VIOLATION – ACTION REQUIRED

November 7, 2008

RE: Scioto County
Scioto Water, Inc.-Rose Hill
Public Community
PWS ID: OH7300303

Scioto Water Inc.
4707 Gallia Pike
Franklin Furnace, OH 45629

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During October 2008 (Monthly)**

Scioto Water, Inc.-Rose Hill is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:

1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
2. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served. The appropriate methods for your system are listed below.

Public Community

- Mail or other direct delivery to each customer
- If necessary to reach all persons regularly served, use other notification methods also, such as newspaper publication, public posting or Internet posting


Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

Scioto Water, Inc.-rose Hill
November 7, 2008
Page 2

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - Southeast District Office. Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at 740-380-5207 or via email to sarah.wallace@epa.state.oh.us

Sincerely,



Sarah Wallace
Environmental Engineer

SW/cb

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

pc: Scioto County Health Department
Southeast District Office Files
Information Management Section, DDAGW, CO