



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



May 8, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Richard J West
115 School Ave, PO Box 335
Corning, OH 43730-0523

Perry County
Southern Perry Co-Irish Ridge
COMMUNITY PWS
PWS ID: OH6434912

Dear Mr. West:

SOUTHERN PERRY CO-IRISH RIDGE is in violation of the Ohio Administrative Code (OAC) for failure to maintain a minimum chlorine residual in their system as required by OAC 3745-83-01.

In accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), community water systems are required to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system. Southern Perry Irish Ridge reported levels of chlorine in the system below the required level on four (4) occasions during the month of April 2012.

If you have any questions please call Sarah Wallace at (740) 380-5207 or via email to sarah.wallace@epa.state.oh.us.

Sincerely,

Sarah Wallace
Environmental Engineer
Ohio EPA-SEDO

SW/cb

ec: SEDO DDAGW AA (State Violation)