



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



June 1, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Charles D Williams
9944 Wilkshire Boulevard
Bolivar, OH 44612

Tuscarawas County
TCMSD-Ridgewood PWS
COMMUNITY PWS
PWS ID: OH7901912

Dear Public Water System Owner:

The Public Water System serving TCMSD-Ridgewood PWS is in violation of the Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1).

In accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), community water systems are required to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system.

According to the April 2012, Monthly Operating Report (MOR) TCMSD-Ridgewood PWS recorded six samples in which the chlorine residual was below the required 0.2 mg/L free or 1.0 mg/L combined in the distribution system.

If you have any questions please call me at 740-380-5216.

Sincerely,

Taylor Carpenter
Environmental Specialist II

TC/cb

ec: Jamie Wilkins, SEDO DDAGW AA (State Violation)