



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



* D D G W O H 6 2 0 1 9 1 1 8 4 2 7 8 6 5 *

NOTICE OF VIOLATION – ACTION REQUIRED

Ottawa County
Lake Erie Utilities Comp
Transient Non-Community PWS
PWS ID: OH6201911

June 20, 2012

Mr. Jim Arvin, President
Lake Erie Utilities Company
P. O. Box 29
Middle Bass, Ohio 43446

Subject: Notice of Violation – Monthly Operating Report (May 2012)

Dear Mr. Arvin:

In violation of OAC Rule 3745-81-75(C)(4), Lake Erie Utilities Company reported incorrect minimum actual CT values for May 16, 2012.

In violation of OAC Rule 3745-81-75(C)(4), Lake Erie Utilities Company reported incorrect effective disinfectant contact time values for May 16, 2012.

In violation of OAC Rule 3745-81-75(C)(4), Lake Erie Utilities Company reported incorrect required contact time values for May 16 through May 31, 2012.

Lake Erie Utilities must review plant operating records and submit a revised monthly operating report for May 2012 immediately. The revised monthly operating reports must be signed by the operator in responsible charge.

Mr. Jim Arvin, President
June 20, 2012
Page 2

If you have any questions regarding this letter or any other matter regarding your water system, please feel free to contact me at (419) 373-4118.

Sincerely,



Justin Bowerman
Environmental Specialist 3
Division of Drinking and Ground Waters

/llr

pc: Ottawa County Health Department
Donald Daley, Uni-Tech Environmental
James Warner, Uni-Tech Environmental
Sam Bundren, Uni-Tech Environmental
Dan Faris, Uni-Tech Environmental
Julie Spangler, DDAGW, CO
Toni Buchanan, DDAGW, CO
DDAGW, NWDO File

ec: Andy Barienbrock, DDAGW, CO
Judy Stottsberry, DDAGW, CO