




**Environmental  
Protection Agency**

John R. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott J. Nally, **Director**



June 22, 2012

**NOTICE OF VIOLATION – ACTION REQUIRED**

Mr. Gary Prowant  
Robins Nest Campground  
2370 North Napoleon Road  
Harrod, Ohio 45850

Allen County  
Robins Nest Campground  
Transient Non-Community PWS  
PWS ID: OH0236412

Dear Mr. Prowant:

The Public Water System serving Robins Nest Campground is in violation of the Ohio Administrative Code (OAC) for:

Failure to respond in Writing within 30 days

*This letter is notification that the Robins Nest Campground (OH0236412) has not complied with requirements issued during this Agency's last survey performed on 5/9/2012, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated 5/15/2012, to respond in writing no later than 30 days, with time frames for:*

1. OAC Rule 3745-81-21 states, "Public water systems shall collect total coliform routine samples at sites which are representative of water throughout the distribution system according to a written sample siting plan".

A Siting Plan for Total Coliform monitoring was not on file. Prepare a Total Coliform Sample Siting Plan as required by OAC Rule 3745-81-21 (draft given to Mrs. Prowant during survey).

If you have any questions, please contact me at (419) 373-3007.

Sincerely,

Clayton McKee  
Division of Drinking and Ground Waters

/llr

pc: DDAGW - NWDO