



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Richland County
MedCentral Health Systems
0370010004
Stack Test
Notice of Violation / HPF

January 29, 2009

CERTIFIED MAIL

Mr. Jim Mishey
MedCentral Health Systems
335 Glessner Avenue
Mansfield, Ohio 44903

Dear Mr. Mishey:

The stack test conducted on November 13-14, 2008, on the Medical Waste Incinerator, Ohio EPA emissions unit No. N004, has been reviewed. The testing was conducted in conformance with Ohio EPA methods and procedures. Our review confirms the following reported data is accurate:

**Critical Test Data
(In Three Run Averages)**

Pollutant	Actual Emission Rate	Allowable Emission Rate	Source Operating Rate	Maximum Source Operating Rate
PM	0.04 lb/hr 0.0060 gr/dscf* 0.0067 lb/100 lbs waste charged	0.72 lb/hr 0.015 gr/dscf* 0.10 lb/100 lbs waste charged	600 lbs/hr	600 lbs/hr
Cd	5.69×10^{-6} lb/hr 8.87×10^{-4} gr/1000 dscf*	0.010 lb/hr 0.07 gr/1000 dscf*	600 lbs/hr	600 lbs/hr

* Corrected to 7% oxygen, dry basis, standard conditions

The compliance demonstration is acceptable and satisfies the compliance demonstration requirements contained in the Title V operating permit. Thank you for your cooperation in this matter.

Mr. Jim Mishey
January 29, 2009
Page 2

However, there is an issue with the timeliness of the submittal of the hard copy test results. The facility has failed to provide Ohio EPA with a written report of test results within thirty days of testing for the stack test. Failure to provide test results within 30 days of testing is a violation of term A.V.1.xiii of the Title V permit, issued 4/18/03. This is also a violation of Ohio Revised Code 3704.05.

The company's written response to this letter is requested by February 27, 2009. It should be submitted to Ohio EPA, Northwest District Office and contain a compliance plan to remedy the situation and prevent this from occurring in the future.

Please note that the submission of information to respond to this letter does not constitute a waiver of Ohio EPA's authority to seek civil penalties pursuant to ORC section 3704.06. The Ohio EPA will make the decision on whether to pursue or decline to pursue such penalties regarding this matter at a later date.

If the company has any questions and/or comments concerning this letter, please contact me at the above address, by calling (419) 373-3137, or electronically via e-mail at thomas.cikotte@epa.state.oh.us.

Sincerely,



Thomas C. Cikotte
Division of Air Pollution Control

/l/r

pc: Lisa Holscher, U.S. EPA Region V
Tom Kalman, DAPC - CO
Don Waltermeyer, DAPC - NWDO
Thomas C. Cikotte, DAPC - NWDO
Robert Teer - NWDO
Stack Test File
ec: Wendy Licht
Tom Sattler
Don Waltermeyer