



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



June 29, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Nick Rettig
Henry County Regional WSD
1857 Oakwood Road
Henry County Office Complex
Napoleon, Ohio 43545

Henry County
Henry County Regional WSD
Community PWS

PWS ID: OH3539212

Subject: Notice of Violation for Failure to Obtain Plan Approval

Dear Mr. Rettig:

OAC Rule 3745-91-02 (A) states "No person shall begin construction or installation of a public water system, or make a substantial change in a public water system, until plans therefor have been approved by the director of environmental protection unless exempted..."

The bulk water fill station was not installed according to the detail plans approved by the Director which constitutes a violation of Section 6109.07 of the Revised Code and Chapter 3745-91 of the Ohio Administrative Code. Violations of the State's safe drinking water laws may result in litigation and the imposition of civil penalties of up to \$25,000 per day of violation.

Plans must be submitted for the bulk water fill station in order to correct this violation.

Please note that additional information concerning existing and upcoming drinking water regulations and requirements can be obtained from our Web site at <http://www.epa.state.oh.us/ddagw/>. If you have any questions regarding this letter, contact Chris Riddle at 419-373- 3101.

Sincerely,

Chris Riddle
Division of Drinking and Ground Waters

/l/r

pc: Poggemeyer Design Group
C.O. - DDAGW / OFAS, Andy Barienbrock
Henry County Health Department
DDAGW-NWDO File

ec: Paul Brock, Linda Benham
Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov

