



**Environmental  
Protection Agency**

John R. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott J. Nelly, **Director**



**NOTICE OF VIOLATION – ACTION REQUIRED**

June 29, 2012

Mr. Ken Jackman  
Hamler Village  
500 East Hubbard Street  
P.O. Box 435  
Hamler, Ohio 43524

Henry County  
Hamler Village  
Community PWS

PWS ID: OH3500312

Dear Mr. Jackman:

The Public Water System serving Hamler Village is in violation of the Ohio Administrative Code (OAC) for failure to comply with the requirements for corrosion control treatment. Specifically, the Hamler Village WTP failed to maintain a pH of at least 7.2 for 23 days during May 2012.

In accordance with the Ohio EPA Director's Letter of March 7, 2011, and OAC 3745-83-01(F)(8)(a), a minimum pH of 7.2 must be maintained and Ohio EPA allows nine days in violation of this parameter during the reporting period. During the reporting period Hamler Village WTP produced water in violation of the required pH for 10 days.

A public notification must be accomplished by mail or other direct delivery to each customer receiving a bill and to other service connections to which water is delivered by the public water system; and any other method reasonably calculated to reach other persons regularly served by the system. This notice may be accomplished through the next CCR provided to customers.

If you wish to provide notice other than through your CCR and would like an example public notice, please contact me.

If you have any questions you can reach me at (419) 373-3101.

Sincerely,

Chris Riddle  
Division of Drinking and Ground Waters

/cg

pc: DDAGW – NWDO  
Northwest District Office  
347 North Dunbridge Road  
Bowling Green, OH 43402-9398

419 | 352 8461  
419 | 352 8468 (fax)  
www.epa.ohio.gov

