



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**



NOTICE OF VIOLATION – ACTION REQUIRED

June 29, 2012

Mr. John Keyes
Oakwood Village Water
228 North First Street
PO Box 457
Oakwood, Ohio 45873

Paulding County
Oakwood Village Water
Community PWS
PWS ID: OH6300312

Dear Mr. Keyes:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. There were 3 weeks during the month of May 2012 in which manganese exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(6) to determine compliance with the secondary maximum contaminant level for manganese.
- (b) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for manganese does not require public notification. **Oakwood has been in violation of OAC 3745-82-02 ten of the past twelve months. Review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.**

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at (419) 373-3101 or via e-mail to chris.riddle@epa.state.oh.us.

Sincerely,

Chris Riddle
Environmental Specialist 2
Division of Drinking and Ground Waters

/cg

pc: Paulding County Health Department
NWDO – DDAGW File

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov

