





**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**

Re: Mercer County
ODOT Mercer County Garage
NTNC Water System
PWS ID # OH5440112

June 28, 2012

Mr. Lonnie C. Falknor
ODOT Mercer County Garage
1001 St. Marys Avenue
Sidney, Ohio 45365

Dear Mr. Lonnie C. Falknor:

This letter will confirm removal of the water use advisory required in our letter dated June 25, 2012. This is based on one set of four total coliform negative (safe) samples collected on June 18, 2012.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by July 11, 2012.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of June 2012.

Yours truly,

Ralph J. Baker
Division of Drinking and Ground Waters

/llr

pc: Ann Scott, IFM
Mercer County Health Department
DDAGW, NWDO File

(

(