



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Wood County
0387020378
American Municipal Power
Relative Accuracy Test Audit

August 18, 2009

Caitlin Schiebel
American Municipal Power – Ohio
2600 Airport Drive
Columbus, Ohio 43219

Dear Ms. Schiebel:

The Relative Accuracy Test Audit conducted on July 16, 2009, on Ohio EPA emissions unit No. P001, has been received and reviewed. The purpose of this letter is to notify you that the CEMS did not meet the required relative accuracy of 0.015 lb/mmBTU for NO_x (violation of 40 CFR Part 75 Appendix B (Figure 2)). It will therefore be necessary to perform another test. You will need to contact your county engineer (Mohammad Smidi) at (419)-373-3118 regarding this matter. Thank you.

Sincerely,

Robert Teer
Division of Air Pollution Control

/csl

pc: Mohammad Smidi
Robert Teer
NWDO file
DAPC RATA File

ec: Wendy Licht
Tom Sattler
Don Waltermeyer