



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Mally, **Director**



July 5, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Todd Smith
Easy Campground and Restaurant
14338 Townline Kossuth Road
St. Marys, Ohio 45885

Auglaize County
Easy Campground and Restaurant
Transient Non-Community PWS
PWS ID: OH0634712

Dear Mr. Smith:

The Public Water System serving Easy Campground and Restaurant is in violation of the Ohio Administrative Code (OAC) for:

Failure to respond in Writing within 30 days

This letter is notification that the Easy Campground and Restaurant (OH0634712) has not complied with requirements issued during this Agency's last survey performed on May 23, 2012, is in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated May 30, 2012, to respond in writing no later than 30 days, with time frames for:

1. OAC Rule 3745-9-05(P) states "Electrical conduit connections on the well cap or seal shall be threaded and sealed to prevent the entrance of insects and water. A well cap for a public water system well shall conform with "Water System Council Pitless Adapter Standard PAS-97, Performance Standards for Sanitary Water Well Pitless Adapters, Pitless Units, and Watertight Well Caps" (1997), or with an alternative standard acceptable to the director."
Repair or replace the electrical conduit connection with a threaded or sealed connection.

If you have any questions, please contact me at (419) 373-3007.

Sincerely,

Clayton McKee
Division of Drinking and Ground Waters

/llr

pc: DDAGW – NWDO File

