



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St.
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 12, 2009

Medway Elementary School
Mike Lucas
9830 West National Rd.
New Carlisle, OH 45344

Clark County
Medway Elementary School
Non-Transient/Non-Community
Public Water System
PWS ID: OH1238312

NOTICE OF VIOLATION: Authority: OAC Rule 3745-81(80 through 89).

Dear Mr. Lucas:

Ohio Administrative Code rule 3745-81-80 requires Medway Elementary School to sample consumers' taps for lead and copper. Lead test results of 21.9 ug/l for the June 1-September 30, 2008 reduced sampling period show the lead action level was exceeded. The action level for lead is 15 ug/l. In a letter dated 11/13/2008 you were notified of this exceedance and required to:

1. Complete water quality sampling by 1/13/2009;
2. Complete a corrosion control study by 6/30/2009; and
3. Complete entry point lead and copper testing and evaluate the raw water source.

Your system has failed to complete the required actions 1, 2, and 3 listed above and is in violation of the above noted rules. In order to come into compliance you must complete the above mentioned requirements immediately. **Please submit the water quality monitoring results and the corrosion control study as required by June 30, 2009.**

If you have any questions, please contact me at (937) 285-6476.

Sincerely,

Bob Moore, Environmental Specialist 2
Division of Drinking and Ground Waters

BM/ca