



State of Ohio Environmental Protection Agency  
Southwest District Office

401 E. Fifth St.  
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 24, 2008

RE: CHAMPAIGN COUNTY  
LIGHTHOUSE TABERNACLE CHURCH  
TRANSIENT NON-COMMUNITY  
PWS ID# 1136612  
**HAND DELIVERY**

Lighthouse Tabernacle Church Board of Trustees  
Attn: Charlene Culp  
P.O. 188  
Tremont City, Ohio 45372

RE: Detailed Plans Submittal Notice of Violation  
Lighthouse Tabernacle Church, 5202 Upper Valley Pike, Urbana, Ohio

Dear Trustees:

Rule 3745-91-02(A) of the Ohio Administrative Code (OAC) states that no person shall begin construction or installation of a public water system, or make a substantial change in a public water system, until plans therefor have been approved by the director of environmental protection. An application for approval of plans for such construction, installation, or substantial change in a public water system, as required by section 6109.07 of the Revised Code, shall be submitted to the district office and shall consist of three copies of plan drawings as specified by OAC 3745-92-03; one copy of specifications as per OAC 3745-91-04; one copy of a data sheet; one copy of supporting information as specified by OAC 3745-91-06; and a submittal letter as specified by OAC 3745-91-07.

Ohio Administrative Code 3745-91-02(B) states that a person applying for a plan approval for a public water system under section 6109.07 of the Revised Code shall pay a fee of one hundred and fifty dollars (\$150.00) plus 0.35% of the estimated project cost, except the total fee shall not exceed twenty thousand dollars. The fee shall be paid at the time the application is submitted by tendering a certified check payable to the Treasurer, State of Ohio.

As of June 24, 2008, plans have not been submitted to the southwest district office of the Ohio EPA. Therefore, this plan approval letter of violation is being issued to the church. Plans must be submitted to this office within 45 days of the date of this letter.

Board of Trustees, Lighthouse Tabernacle Church  
June 24, 2008  
Page 2

Submit the plans to:

Ms. Jo Davidson  
Ohio Environmental Protection Agency  
Southwest District Office  
401 East Fifth Street  
Dayton, OH 45402

At this time, the water system is not approved. All bacteria sample results received for March and April 2008, are unsafe. Until plans are submitted, reviewed, and approved, we do not recommend that the water system be operated. If you have any questions, please give me a call at (937) 285-6446 or (800) 686-6930.

Sincerely,

A handwritten signature in black ink, appearing to read "Kathy Lee Fox". The signature is fluid and cursive, with the first name "Kathy" being the most prominent.

Kathy Lee Fox  
Public Drinking Water Unit  
Division of Drinking and Ground Water

cc: Champaign County Health Department  
file