



State of Ohio Environm

OH7602412

Hillview Mobile Court

5/24/2007

STREET ADDRESS:

Lazarus Government Center
50 W Town Street, Suite 700
Columbus, OH 43215

TELE: (614) 644-3020



May 24, 2007

CERTIFIED MAIL

HILLVIEW MOBILE COURT
P O Box 35944
CANTON, OH 44735

Re: STARK COUNTY
HILLVIEW MOBILE COURT
Community Water System
PWS ID: OH7602412
STU ID: 7658290
SMPID: EP001

Arsenic Maximum Contaminant Level (MCL) Exceedance

Dear Public Water System Owner:

This letter is notification that HILLVIEW MOBILE COURT is in violation for exceeding the maximum contaminant level (MCL) standard for arsenic of .010 mg/L as established in the Ohio Administrative Code (OAC) section 3745-81-11. Compliance with the arsenic MCL is based on a running annual average. The annual average for arsenic for the 1st quarter 2007 time period is 0.091 mg/L.

To address the MCL violation the HILLVIEW MOBILE COURT is required to take the following actions:

- 1) ISSUE PUBLIC NOTICE:
Within thirty days, issue public notice according to the enclosed instructions. Complete and return the verification form along with a copy of the public notice to my attention at the letterhead address within ten days after it is issued. If arsenic levels continue to exceed the MCL, the public notification must be updated and repeated for each period that the arsenic MCL is exceeded. A verification form and copy of the public notice must be sent to Ohio EPA each time the notice is repeated. The enclosed draft public notice may be used verbatim. The mandatory health language for arsenic must appear in the public notice. If you wish to make any changes to this draft, telephone this office for verbal authorization prior to issuing the public notice.
- 2) CONTINUE TO SAMPLE FOR ARSENIC:
Continue collecting one sample for arsenic analysis on a quarterly basis. Your next sample should be collected between April 1 and June 30, 2007 .
- 3) WORK TO RESOLVE THE PROBLEM:
Consult with your Ohio EPA district representative to discuss your options for coming into compliance and to establish a compliance schedule.

HILLVIEW MOBILE COURT

5/24/2007

Page Two

If you have questions regarding this correspondence, compliance with the arsenic standard, or questions regarding the public notice requirement, please contact me at (614) 644-2752.

Sincerely,

Kathleen Pinto

Kathleen Pinto
Compliance Assurance Section
Division of Drinking and Ground Waters

Enclosure: Public Notice and Instructions, Verification Form

cc: Superintendent/Manager; NEDO; DDAGW; Todd Kelleher, Supervisor, CU;
STARK County Health Dept.

DRINKING WATER NOTICE

Hillview Mobile Court Public Water System Has Levels of Arsenic Above Drinking Water Standards

Our water system has violated the maximum contaminant level (MCL) for Arsenic. The MCL for arsenic is based on an annual average level of arsenic collected over 4 quarters. The MCL for arsenic is 10 µg/L. At this time, the annual average arsenic level at Hillview Mobile Court is 91 µg/L.

What should I do?

We are ordered by the Stark County Health Department to provide you with an alternative (e.g., bottled) water. If you have specific health concerns, consult your doctor.

What does this mean?

Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

What is being done?

We are required to investigate and take the necessary steps to correct the problem as soon as possible.

For more information, please contact _____ at _____ or _____
name of contact phone number mailing address

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID#: 7602412 STUID#: 7658290 Date distributed: _____

PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR COMMUNITY PUBLIC WATER SYSTEMS WITH TIER 2 VIOLATIONS

The owner or operator of a community public water system with a Tier 2 violation or situation shall notify the persons served by the public water system as soon as practical but **no later than 30 days** after the system learns of the violation. Public notice shall be repeated every 3 months as long as the violation or situation persists.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
<p>Use the following method to reach all persons served by the public water system:</p> <p>Public notice issued by mail or other direct delivery to each customer receiving a bill and to other service connections to which water is delivered by the public water system</p>	<p>Describe actual methods used to notify public of the violation:</p> <p>A. Date of mailing/delivery _____</p> <p>_____</p>
<p>If the above method does not reach all persons served, also use any other method reasonably calculated to reach other persons regularly served by the public water system (e.g. publication in a local newspaper, delivery of multiple copies for distribution by customers that provide their drinking water to others, posting in public places served by the system or on the Internet, or delivery to community organizations). If the notice is posted, it shall remain in place as long as the violation exists, but in no case less than 7 days.</p>	<p>A. Method(s) _____</p> <p>_____</p> <p>_____</p> <p>B. Date(s) _____</p> <p>_____</p>

Please check if the public notice used was provided by Ohio EPA (other side of this form) or another acceptable notice was used:

_____ A public notice as shown on the other side of this sheet was issued without changes.

_____ A different public notice was issued. **INCLUDE A COPY OF THE PUBLIC NOTICE.**

Signature of Responsible Person Date

Printed Name and Title of Responsible Person

For Ohio EPA use only:

Date PN received: _____

PN acceptable: _____ PN not acceptable: _____

HILLVIEW MOBILE COURT
PWS ID: OH7602412
STU ID: 7658290
County: STARK
Violation: Arsenic MCL
Monitoring Period: 1st quarter 2007



State of Ohio Environmental Protection Agency


Division of Drinking Water & Ground Waters (DW)

Carus Government Center


P.O. Box 1049

Columbus, Ohio 43216-1049

EPA - 5026 (Rev.6/99)



91 7108 2133 3931 0973 5830



02 1A \$ 03.91⁰
0004349327 MAY 25 2007
MAILED FROM ZIP CODE 43215

HILLVIEW MOBILE HOME COURT

PO BOX 35944


CANTON OH 44735



HILL944 443 SE 1 N C 02 06/03/07D
UNABLE TO FORWARD/FOR REVIEW

NO FORWARDING ORDER ON FILE
RETURN TO POSTMASTER

OF ORIGINAL ADDRESSEE FOR REVIEW
BC: 44735594444 PM *2073-01760-25-42



5-26

RECEIVED
BOARD

07 JUN -7 AM 10:20

44735594444
44735594444