



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W Town Street, Suite 700
Columbus, OH 43215

TELE: (614) 644-3020
www.epa.s

OH7839512

Maplewood High School

MAILING ADDRESS:

12/4/2008

December 4, 2008



MAPLEWOOD HIGH - MAPLEWOOD LOCAL SCHOOL Re:
2414 GREENVILLE ROAD
CORTLAND, OH 44410

TRUMBULL COUNTY
MAPLEWOOD HIGH SCHOOL
Nontransient Noncommunity Water System
PWS ID: OH7839512

NOTICE OF VIOLATION - ACTION REQUIRED

Subject: Failure to Monitor Drinking Water

Maplewood High School is in violation of Ohio Administrative Code Rule 3745-81-24 for failing to monitor your drinking water during the July 1, 2008 to September 30, 2008 monitoring period and/or report results for the following contaminants: TOTAL HALOACETIC ACIDS (HAA5), TOTAL TRIHALOMETHANES (TTHM)

In order to return to compliance, Maplewood High School must take the following actions:

1. Immediately collect a sample of your drinking water from the maximum residence time (location in system where age of water is oldest).
2. Submit the sample for analysis to a certified laboratory on the enclosed list.
3. Notify your customers using the enclosed instructions and public notice.
4. Complete and return the enclosed verification form to this office.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or if the required sample was tested, please call me at (614) 644-2752.

Sarah Byerly
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form; Laboratory List
cc: Superintendent/Manager; DDAGW-NEDO file; DDAGW-CO file