



State of Ohio Environment OH8505012

Country Pointe Wooster Sub

2/24/2009

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-2752
www.epa.st



NOTICE OF VIOLATION – ACTION REQUIRED

February 24, 2009

Doug Walters
Country Pointe Wooster Sub-acute PWS
3071 N Elyria Rd
Wooster, OH 44691

Wayne County
Country Pointe Wooster Sub-acute PWS
Public Community PWS
PWS ID: OH8505012

Subject: Failure to Monitor Drinking Water

Country Pointe Wooster Sub-acute PWS is in violation of Ohio Administrative Code Rule (OAC) 3745-81-26 for failing to monitor your drinking water during the October 1 to December 31, 2008 monitoring period and/or report results for the following contaminants: Gross Alpha and Radium-228.

In order to return to compliance, Country Pointe Wooster Sub-acute PWS must take the following actions:

1. Immediately collect a sample of your drinking water from the entry point (first tap after treatment).
2. Submit the sample for analysis to a certified laboratory on the enclosed list.
3. Notify your customers using the enclosed instructions and public notice.
4. Complete and return the enclosed verification form to this office.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or if the required sample was tested, please call me at (614) 644-2752.

Sincerely,

Wendy Sheeran

Division of Drinking and Ground Waters

Enclosure: Laboratory List, Public Notice, Verification Form

cc: Manager; District: DIV DDAGW-NEDO file, DDAGW-CO file

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director