



2PR0000920110725

ASHLAND CINNAMON LAKE ASSOCIATION WWTP 2PR00009 2011/07/25 ARISS, WALTER WEST SALEM



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Ashland County
Cinnamon Lake
NPDES Permit

July 25, 2011

Mr. Eugene Sheridan
Cinnamon Lake Utilities Association
1443 Laurel Drive
West Salem, Ohio 44287

Dear Mr. Sheridan,

On July 7, 2011, an inspection was made of the wastewater treatment facilities serving the Cinnamon Lake subdivision located at 1443 Laurel Drive, West Salem, Ashland County. At the time of the inspection all major treatment units were in service. Mr. Codi Pitsenbarger, wastewater plant operator, was present to answer questions regarding treatment plant operations.

At the time of the inspection all major treatment units were in service and appeared to be functioning normally. No major concerns with the treatment plant operations were noted. During the inspection we discussed the upcoming construction project and improvements to the treatment plant.

Please be aware that your NPDES discharge permit contains a compliance schedule to construct plant upgrades. The next milestone in this schedule is to advertise for construction bids no later than November 1, 2011. Construction shall begin no later than May 1, 2012.

A review of the facility's discharge monitoring reports from the months of July 2010, through May 2011, revealed numerous **violations** of the limits contained in your NPDES permit. A summary of these violations is enclosed on a separate sheet.

If you have any questions please call me at 419-373-3070.

Sincerely,

Walter Ariss
Environmental Specialist II
Division of Surface Water

/llr

Enclosure

pc: DSW-NWDO File

Get New Data		Cinnamon Lake NPDES permit limit violations July 2010 through May 2011						
Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PR00009*KD	July 2010	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.0	1.30313	7/1/2010
2PR00009*KD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.038	.06	7/9/2010
2PR00009*KD	July 2010	001	00610	Nitrogen, Ammonia (NH3	1D Conc	1.5	2.67	7/13/2010
2PR00009*KD	July 2010	001	00610	Nitrogen, Ammonia (NH3	1D Conc	1.5	1.97	7/14/2010
2PR00009*KD	August 2010	001	00300	Dissolved Oxygen	1D Conc	5.0	3.24	8/1/2010
2PR00009*KD	August 2010	001	00300	Dissolved Oxygen	1D Conc	5.0	4.32	8/2/2010
2PR00009*KD	September 2010	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.0	1.03138	9/1/2010