



2PR0012120080507

ASHLAND | COUNTRY STAGE CAMPGROUNDS | 2PR00121 | 2008/05/07 | ARISS, WALTER | NOVA



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Ashland County
Country Stage Campgrounds
NPDES Permit
Notice of Violation

May 7, 2008

Mrs. Nancy Plain
Country Stage Campgrounds
40 County Road 1031
Nova, Ohio 44859

Dear Mrs. Plain:

On April 24, 2008, an inspection was made of the wastewater treatment facilities serving the Country Stage Campgrounds located at 40 County Road 1031, Troy Township, Ashland County. At the time of the inspection the wastewater treatment plant was not operating. The campground had not yet opened for this year, so the plant was still turned off.

At the time of the inspection the new control box had not yet been installed on the sand filter dosing station. A letter received from Eastwood Environmental on October 4, 2007 stated that the control box would be installed in the spring of 2008. As it is now May, the control panel should be installed as soon as possible. We consider your facility **to be in violation** of the conditions of your NPDES permit until the control panel unit is installed.

A new chlorine tablet feeder box had been installed in the chlorine contact tank; however the baffles within the tank have yet to be repaired. It was also undetermined if the chlorine tank had been resealed as mentioned in our previous letter. These items should be completed as soon as possible.

A review of the monthly reports submitted for the months of August 2007 through March 2008 revealed several **violations** of the limits contained in your NPDES permit. The majority of these were for exceeding the ammonia limit.

Our office is aware that the campground has been sold. I have enclosed an NPDES permit transfer application form. It will be necessary for you to complete the form in order to transfer the permit to the new owner. Complete the form and submit it to our office **within 14 days** of receipt of this letter. Please be aware that you are still legally responsible for the treatment plant discharge until the permit is transferred to the new owner.

Mrs. Nancy Plain
May 7, 2008
Page 2

If you have any questions please call me at 419-373-3070.

Sincerely,



Walter Ariss
Environmental Specialist II
Division of Surface Water

/llr

Enclosure

pc: D\SW-NWDO\Files\w\enclosure [?]
Pamela McCreary
Derrick Shinault, Eastwood Environmental w/enclosure
John Cadley, Ashland County Health Department

NPDES permit limit violations August 2007 through March 2008

Country Stage Campground

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PR00121*BD	August 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	7.225	8/1/2007
2PR00121*BD	August 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.045	.16408	8/1/2007
2PR00121*BD	August 2007	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	8.87	8/8/2007
2PR00121*BD	August 2007	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.068	.20144	8/8/2007
2PR00121*BD	August 2007	001	00400	pH	1D Conc	6.5	6.4	8/21/2007
2PR00121*BD	August 2007	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	5.58	8/22/2007
2PR00121*BD	August 2007	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.068	.12672	8/22/2007
2PR00121*BD	September 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	53.	9/1/2007
2PR00121*BD	September 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.045	1.20363	9/1/2007
2PR00121*BD	September 2007	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	53.	9/15/2007
2PR00121*BD	September 2007	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.068	1.20363	9/15/2007
2PR00121*BD	October 2007	001	00530	Total Suspended Solids	30D Conc	12	16.	10/1/2007
2PR00121*BD	October 2007	001	00400	pH	1D Conc	6.5	6.3	10/16/2007