



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

February 17, 2009

RE: KENT WATER RECLAMATION FACILITY  
NPDES #3PD00031  
FEBRUARY 11, 2009  
COMPLIANCE INSPECTION

Mr. Robert Brown  
City of Kent  
641 Middlebury Road  
Kent, OH 44240

Dear Mr. Brown:

This letter will document the above compliance inspection. A review of monitoring data indicated one effluent limit permit violation during the time period January 2008 through December 2008.

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
February 2008	Mercury, Total	Monthly Concentration	2.4	3.9	2/1/2008
July 2008	Bis(2-ethylhexyl) Phthalate	Monthly Concentration	12	945	7/1/2008
July 2008	Bis(2-ethylhexyl) Phthalate	Monthly Loading	0.228	7.15	7/1/2008
July 2008	Bis(2-ethylhexyl) Phthalate	Maximum Concentration	1870	1890	7/8/2008
August 2008	Bis(2-ethylhexyl) Phthalate	Monthly Concentration	12	12.3	8/1/2008

The water reclamation facility continues to be well maintained and operated. A review of MORs for the above time period demonstrates that the plant continues to produce a high quality effluent.

Parameter	Effluent Data		
	Average	Median	Maximum
Phosphorus (mg/l)	0.64	0.60	1.1
Flow (MGD)	2.57	2.30	6.90
BOD <sub>5</sub> (mg/l)	1.68	2.00	3
TSS (mg/l)	3.08	3.00	9
%BOD <sub>5</sub> Removal	99.99	99.99	

Should you have further questions, please call me at (330) 963-1134.

Sincerely,

William J. Zawiski  
Environmental Scientist  
Division of Surface Water

WJZ/mt