



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 27, 2007

RE: KENT WATER RECLAMATION FACILITY
NPDES #3PD00031
AUGUST 24, 2007
COMPLIANCE INSPECTION

Mr. Robert Brown
City of Kent
641 Middlebury Road
Kent, OH 44240

Dear Mr. Brown:

This letter will document the above compliance inspection. A review of monitoring data indicated one effluent limit permit violation during the time period October 2006 through July 2007.

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
April 2007	001	Copper, TR	30D Conc.	17	27	4/1/2007

The water reclamation facility continues to be well maintained and operated. A review of MORs for the above time period demonstrates that the plant is producing a high quality effluent.

Parameter	Effluent Data		
	Average	Median	Maximum
Phosphorus (mg/l)	0.40	0.40	0.50
Flow (MGD)	2.39	2.30	6.20
BOD ₅ (mg/l)	1.68	2.00	3.00
TSS (mg/l)	2.55	2.25	9.00
DO (mg/l)	9.81	10.00	10.00
%BOD ₅ Removal	99.0	99.0	99.7

Should you have further questions, please call me at (330) 963-1134.

Sincerely,

William J. Zawiski
Environmental Scientist
Division of Surface Water

WJZ/mt