



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 11, 2010

RE: Kent Water Reclamation Facility
NPDES #3PD00031
February 10, 2010
Compliance Inspection

Mr. Robert Brown
City of Kent
641 Middlebury Road
Kent, OH 44240

Dear Mr. Brown:

This letter will document the above compliance inspection. A review of monitoring data indicated one effluent limit permit violation during the time period January 2009 through December 2009.

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
September 2009	001	Bis(2-ethylhexyl) Phthalate	30D Conc	12	17.	9/1/2009

The water reclamation facility continues to be well maintained and operated. A review of MORs for the above time period demonstrates that the plant continues to produce a high quality effluent as shown in the table below.

Parameter	Effluent Data		
	Average	Median	Maximum
Phosphorus (mg/l)	0.6	0.6	0.93
Flow (MGD)	2.4	2.1	10.7
BOD ₅ (mg/l)	0.8	0	3
TSS (mg/l)	1.9	0	7
Ammonia (mg/l)	0.04	0	1.3
%BOD ₅ Removal		99.5%	

Should you have further questions please call me at (330) 963-1134.

Sincerely,

William J. Zawiski
Environmental Scientist
Division of Surface Water

WJZ/mt