



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 13, 2007

RE: COLUMBIANA COUNTY
VILLAGE OF LEETONIA
NPDES PERMIT NO. 3PB00017
LEETONIA WWTP
2 SAINT PETERS STREET

Mr. Gary Phillips
Village Administrator
Village of Leetonia
300 East Main Street
Leetonia, OH 44431-1197

Dear Ladies and Gentlemen:

On June 6, 2007, this writer conducted an inspection of Leetonia Wastewater Treatment Plant, located at 2 St. Peters Street, Leetonia, Ohio. Representing the Village during the inspection was Junita Grant. The purpose of the inspection was to review the water pollution control facilities and evaluate compliance with the facility's National Pollutant Discharge Elimination System (NPDES) permit. The following was observed at the time of the inspection:

- 1) The facility appeared well maintained and well operated. A review of the last two years and five months of monthly operating report data revealed only two violations of the NPDES permit effluent discharge criteria.
- 2) At the time of the inspection, all treatment processes appeared satisfactory. The aeration tanks had good color, and the clarifiers had some minor pin floc. The effluent appeared satisfactory as it discharged to the East Branch of the Middle Fork of Little Beaver Creek.

The draft permit will be available for your review shortly.

Should you have any comments or concerns regarding this letter, please feel free to contact me at (330) 963-1193.

Respectfully,

Joseph E. Trocchio, P.E.
Environmental Engineer
Division of Surface Water

JET/mt

cc: Butch Donnalley, Superintendent

File: Public/Permit Compliance/Leetonia Wastewater Treatment Plant