



**Environmental
Protection Agency**

John Kasich, Governor
Mike DeWine, Lt. Governor
Chris Grzeski, Director

June 29, 2010

RE: VILLAGE OF MILLERSBURG WWTP
NPDES #3PC00100
2010 CEI

Mayor and Council
Village of Millersburg
6 North Washington Street
Millersburg, OH 44654

Ladies and Gentlemen:

On June 28, 2010, this writer along with Dean Stoll and Paul Andersen conducted an inspection of the Millersburg POTW. The intent of the inspection was to evaluate operations and maintenance of the system and to evaluate compliance with the NPDES Permit. Kevin Vaughn represented the village during the inspection.

Following are observations made during the inspection.

1. It appeared that all processes were operational during the inspection. Two clarifiers used during periods of high flow into the plant were not on-line at the time of the inspection.
2. The aeration tank had good mixing and color.
3. The clarifier effluent was clear with little turbidity. The sludge appeared to have good settling quality.
4. The effluent at the disinfection tank was clear.
5. No impact on the stream was apparent at the discharge location to Killbuck Creek; however, the area had recently experienced a heavy precipitation event causing the creek to be turbid and have a high velocity.
6. It was the understanding of this writer that no headworks bypasses or overflows within the collection system exist that could discharge untreated wastewater to area streams.
7. It was the understanding of this writer that the emergency generator is exercised once per week, and that the generator was able to operate the entire plant.

A review of your self-monitoring reports covering the period of March 2009 through May 2010 revealed the following effluent violations:

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
August 2009	Nitrogen, Ammonia	7D Concentration	2.3	3.63333	8/8/2009
February 2010	Oil and Grease, Freon	1D Concentration	10	10.3	2/19/2010

Northeast District Office
2110 East Aurora Road
Twinsburg, OH 44087-1924


330 | 963 1200
330 | 487 0769 (fax)
www.epa.ohio.gov

Mayor and Council
Village of Millersburg WWTP
June 29, 2010
Page 2

Be advised that violations of the NPDES Permit constitute violations of the Ohio Revised Code (R.C.) 6111.07.

You may contact this writer at (330) 963-1251 or at john.kwolek@epa.state.oh.us in the event you have any questions or comments regarding this letter.

Sincerely,



John Kwolek
District Engineer
Division of Surface Water

JK/mt

cc: Kevin Vaughn, Millersburg WWTP
Kevin Brooks, Village Administrator
Larry Reeder, Ohio EPA, DSW, CO
Gretchen Fickle, DEFA