



**Environmental
Protection Agency**

_____, Governor
_____, Lt. Governor
_____, Director

November 19, 2010

RE: CITY OF LOUISVILLE WWTP
NPDES 3PD00033
STARK COUNTY

Mr. Bill Glick, Superintendent
City of Louisville
215 South Mill St.
Louisville, OH 44641-1699

Dear Mr. Glick:

A review of the City of Louisville compliance milestones contained in NPDES permit 3PD00033*HD by this office has revealed a couple of issues that must be resolved. Compliance milestones specified in Part I, C, B(2 and 3) have not been met. The compliance dates are as follows:

B. E. coli Monitoring and Limits

1. The permittee shall evaluate the ability of its existing treatment facilities to meet the final effluent limit for E. coli at outfall 3PD00033001.

2. Within 4 months from the effective date of this permit, the permittee shall submit to the Ohio EPA Northeast District Office a brief status report on the ability of its existing treatment facilities to meet the final effluent limit for E. coli. (Report due no later than August 6, 2010)

3. If the permittee determines that its existing treatment facilities are not capable of meeting the final effluent limit for E. coli, not later than 6 months from the effective date of this permit, the permittee shall submit an approvable Permit To Install for plant improvements necessary to meet the final effluent limit for E. coli. (PTI if necessary due by October 6, 2010)

Have you determined that you can meet the final E. coli limits? If so, then provide a letter to this office stating this for the record. If you cannot meet the E. coli limit then a PTI is past due and must be submitted as soon as possible. Please be advised that the City of Louisville is in violation of the permit for at least item 2 above. Depending upon the status of meeting the E. coli limit, a second violation may exist for not submitting the PTI Application.

Mr. Bill Glick, Superintendent
City of Louisville
November 19, 2010
Page 2

We request that you come into compliance with the above milestones as soon as possible. Please submit a letter detailing your intention to resolve the noncompliance issues with an expedited time frame no later than November 30, 2010.

If you have any questions or comments regarding this letter, please feel free to contact this office at (330) 963-1136.

Sincerely,



Philip P. Rhodes, P.E.
Environmental Specialist II
Division of Surface Water

PPR/mt

cc: Mayor and Council, City of Louisville
James McBeath, Director of Service Operations, City of Louisville
Dean Stoll, Enforcement Coordinator, Ohio EPA, DSW, NEDO

File: Public/Permit Compliance