



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

June 2, 2008

RE: SELF-MONITORING REPORT VIOLATION
LAKE COUNTY
PAINESVILLE WWTP
OEPA PERMIT NO. 3PD00029
NPDES PERMIT NO. OH0026948

Mr. Randy Bruback
Painesville Water Pollution Control Plant
1170 North State Street
P.O. Box 601
Painesville, OH 44077

Dear Mr. Bruback:

This office has recently reviewed your self-monitoring reports covering the month of March 2008 for the referenced facility. Our review indicates violations of the terms and conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	7D Qty	409	488.908	3/15/2008

Please be advised that such instances of noncompliance may be cause for enforcement actions pursuant to the Ohio Revised Code, Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reason for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Should you have questions or comments regarding this notification, please contact this writer at (330) 963-1183.

Sincerely,

Marie Underwood, P.E.
Environmental Engineer
Division of Surface Water

MU/mt