



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 19, 2009

RE: MAHONING COUNTY  
BERLIN TWP.  
MILL CREEK REC. AREA  
NPDES PERMIT NO 3PN00000

Mr. Rene' Berberich  
USACOE, Mill Creek Rec. Area  
7400 Bedell Road  
Berlin Center, OH 44401

Dear Mr. Berberich:

On July 2, 2009, this writer conducted an inspection of the wastewater treatment system for the Mill Creek Recreational Area located at 7400 Bedell Road. At the time of the inspection, the treatment system was satisfactory. The aeration tank had good color and the clarifier weir and trough was clean. The effluent was clear with no color and no identifiable odor.

The compliance record for the treatment system was reviewed as part of this inspection. The period of review was August 2008 through July 2009. Following are violations of the NPDES Permit that were reported during the review period.

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2009	Fecal Coliform	30-Day Conc.	1000	1000	6/1/2009
June 2009	Total Suspended Solids	7-Day Qty.	2.0	2.71574	6/15/2009

In addition to the limit violations above, the following frequency violations were identified for failing to report in accordance with the NPDES Permit.


Reporting Period	Parameter	Sample Frequency	Expected	Reported	Violation Date
Sept. 2008	Phosphorus, Total (P)	1/Quarter	1	0	09/01/2008
May 2009	Phosphorus, Total (P)	1/Quarter	1	0	05/01/2009

It is recommended that you review the NPDES Permit to ensure that the facility is reporting as required. Failing to submit analytical results in accordance with the NPDES Permit is a violation of the permit and Ohio Revised Code 6111.07.

MR. RENE' BERBERICH  
AUGUST 19, 2009  
PAGE 2

You may contact this writer at (330) 963-1251 to discuss any questions you may have.

Respectfully,

A handwritten signature in black ink, appearing to read "John Kwolek". The signature is written in a cursive style with a large, looping initial "J".

John Kwolek  
District Engineer  
Division of Surface Water

JK:bo

pc: Joe Mansky, Mahoning County Health Department