



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 19, 2007

RE: CITY OF SEVILLE
SEVILLE POTW
2007 CEI

Mr. Kevin Bittaker
Superintendent
4835 Mill Road
Seville, OH 44273

Dear Mr. Bittaker:

On May 31, 2007, this writer conducted an inspection of the Seville POTW. The intent of the inspection was to confirm information provided in the National Pollutant Discharge Elimination System (NPDES) permit renewal application.

At the time of the inspection, the condition of the treatment plant was considered satisfactory. Operations identified were influent pumping, influent screening, grit removal, aeration in a sequencing batch reactor, final clarification, ultraviolet disinfection and post aeration. All treatment processes were in operation at the time of the inspection. The ultraviolet disinfection system was recently put on-line and replaced the chlorination system previously used for disinfection.

The effluent at the time of the inspection was clear and free from color and turbidity. The receiving stream at the point of discharge was free of solids deposition.

As part of this inspection, the compliance status of the Seville POTW was reviewed. The record of review was the Monthly Operating Reports for the period covering May 2006 through April 2007. Following are violations identified at Outfall 001 for the review period.

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2006	Zinc, Total Recoverabl	1D Qty	0.4	.59945	6/21/2006
July 2006	Nitrogen, Ammonia (NH3	7D Conc	2.3	3.45	7/1/2006
July 2006	Nitrogen, Ammonia (NH3	7D Qty	4.4	6.45021	7/1/2006
July 2006	Nitrogen, Ammonia (NH3	7D Conc	2.3	3.5	7/8/2006
July 2006	Nitrogen, Ammonia (NH3	7D Qty	4.4	7.6862	7/8/2006
July 2006	Nitrogen, Ammonia (NH3	7D Conc	2.3	2.65	7/15/2006
July 2006	Nitrogen, Ammonia (NH3	30D Conc	1.5	3.1375	7/1/2006
July 2006	Nitrogen, Ammonia (NH3	7D Conc	2.3	2.95	7/22/2006
July 2006	Nitrogen, Ammonia (NH3	30D Qty	2.8	5.54834	7/1/2006

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
January 2007	Nitrogen, Ammonia (NH3)	30D Conc	3.5	4.18	1/15/07
January 2007	Nitrogen, Ammonia (NH3)	30D Qty	6.5	12.5304	1/15/07
January 2007	Nitrogen, Ammonia (NH3)	7D Qty	10.1	12.5304	1/15/07

Be advised that violations of the NPDES permit constitute violations of Code 6111.07 and are subject to enforcement action. No Revised

You may contact this writer at (330) 963-1251 to discuss any questions you may have.

Respectfully,



John Kwolek
District Engineer
Division of Surface Water

JK/mt

File: Public/Seville/Permits and Compliance