

U.S. Postal Service
CERTIFIED MAIL RECEIPT
(Domestic Mail Only, No Insurance Coverage)

7010 1060 0000 0089 7285

Postage and Fees Due (If Payment is Made by Addressee, Indicate Amount in Dollars and Cents)
\$

Postage	\$	Postmark Here
Certified Fee		
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
Total Postage & Fees	\$	

Sent To

Street, Apt. No.,
or PO Box No.

City, State, ZIP+4

**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Koreski, Director

October 6, 2010

RE: WAYNE COUNTY
CITY OF WOOSTER
NPDES# 3PD00013

NOTICE OF VIOLATION

CERTIFIED MAIL

Mayor Robert Breneman
City of Wooster
1020 Old Columbus Road
Wooster, Ohio 44691-4618

Dear Mayor Breneman:

A summary of the City of Wooster's wastewater treatment plant discharge violations for outfall 001 for the months of July 2010 and August 2010 are shown below:

Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
July 2010	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	2.19	2.6	7/8/2010
July 2010	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	62	65.8151	7/8/2010
July 2010	001	00300	Dissolved Oxygen	1D Conc	7.0	6.5	7/10/2010
July 2010	001	00300	Dissolved Oxygen	1D Conc	7.0	5.9	7/25/2010
August 2010	001	00300	Dissolved Oxygen	1D Conc	7.0	6.1	8/14/2010
August 2010	001	00300	Dissolved Oxygen	1D Conc	7.0	4.9	8/21/2010

Our office is in receipt of the City's August 23, 2010 and September 21, 2010 letters addressing the above noted violations. Plant data shows an increase in organic loading for the months and has been operating above design loads.

The ammonia violation was attributable to the organic load conditions exceeding design limitations at the plant. The plant was unable to complete nitrification with the available aeration capacity. The dissolved oxygen exceedances are covered under the "permitted high flow caused excursions" as stated in Part II – Item M of the City's NPDES permit.

The City is currently in the process of constructing the biotower near the Frito Lay property. A PTI has been issued by the Ohio EPA for the biotower project. It is understood that, as of September 2010, the project is behind schedule. The City has estimated completion of construction to be in December 2010.

Mayor Robert Breneman
City of Wooster
October 6, 2010
Page 2

If you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Respectfully,



Todd Surrena
Engineering Geologist
Division of Surface Water

TMS/mt

- pc: Mr. Jim Borton, Utilities Manager
Mr. Lee Troyer, Pretreatment Coordinator
Wayne County Health Dept.
- ec: Rich Blasick, P.E., Ohio EPA, DSW, NEDO
Dean Stoll, P.E., Ohio EPA, DSW, NEDO
Larry Reeder, Ohio EPA, DSW Enforcement, Central Office
Bill Fischbein, Ohio EPA, Legal, CO
Dennis Deniro, Ohio EPA, DEFA, CO

**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

January 5, 2011

RE: WAYNE COUNTY
CITY OF WOOSTER
NPDES# 3PD00013

NOTICE OF VIOLATION

CERTIFIED MAIL

Mayor Robert Breneman
City of Wooster
1020 Old Columbus Road
Wooster, Ohio 44691-4618

Dear Mayor Breneman:

A summary of the City of Wooster's wastewater treatment plant discharge violations for outfall 001 for the months of September 2010, October 2010 and November 2010 are shown below:

Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
September 2010	001	00300	Dissolved Oxygen	1D Conc	7.0	5.6	9/16/2010
September 2010	001	00300	Dissolved Oxygen	1D Conc	7.0	6.6	9/28/2010
October 2010	001	00530	Total Suspended Solids	30D Conc	16	18.5	10/1/2010
October 2010	001	00530	Total Suspended Solids	7D Conc	24	48.	10/15/2010
October 2010	001	00530	Total Suspended Solids	7D Qty	682	748.264	10/15/2010
October 2010	001	00530	Total Suspended Solids	7D Conc	24	26.	10/22/2010
November 2010	001	00530	Total Suspended Solids	30D Conc	16	64.15	11/1/2010
November 2010	001	00530	Total Suspended Solids	30D Qty	455	2429.17	11/1/2010
November 2010	001	80082	CBOD 5 day	30D Conc	10	15.3571	11/1/2010
November 2010	001	80082	CBOD 5 day	30D Qty	284	450.606	11/1/2010
November 2010	001	00530	Total Suspended Solids	7D Conc	24	49.3333	11/8/2010
November 2010	001	80082	CBOD 5 day	7D Conc	15	16.3333	11/8/2010
November 2010	001	00530	Total Suspended Solids	7D Conc	24	120.166	11/22/2010
November 2010	001	00530	Total Suspended Solids	7D Qty	682	5424.82	11/22/2010
November 2010	001	00300	Dissolved Oxygen	1D Conc	5.0	3.2	11/25/2010
November 2010	001	00300	Dissolved Oxygen	1D Conc	5.0	4.8	11/30/2010

Our office is in receipt of the City's October 25, 2010, November 22, 2010 and December 22, 2010 letters addressing the above noted violations. Plant data shows an increase in organic loading for the months and has been operating above design loads.

The CBOD and total suspended solids violations are attributable to the organic load conditions exceeding design limitations at the plant. The two September and November

Mayor Robert Breneman
City of Wooster
January 5, 2011
Page 2

30 dissolved oxygen exceedances are covered under the "permitted high flow caused excursions" as stated in Part II – Item M of the City's NPDES permit. The November 25 dissolved oxygen exceedance is a violation.

The City is currently in the process of constructing the biotower near the Frito Lay property. A PTI has been issued by the Ohio EPA for the biotower project. It is understood that, as of December 2010, the project is behind schedule. The City has estimated completion of construction by January 2011 and start up activities are scheduled for the week of January 10, 2011.

If you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Respectfully,



Todd Surrena
Engineering Geologist
Division of Surface Water

TMS/mt

pc: Mr. Jim Borton, Utilities Manager
Mr. Lee Troyer, Pretreatment Coordinator
Wayne County Health Dept.

ec: Rich Blasick, P.E., Ohio EPA, DSW, NEDO
Dean Stoll, P.E., Ohio EPA, DSW, NEDO
Larry Reeder, Ohio EPA, DSW Enforcement, Central Office
Bill Fischbein, Ohio EPA, Legal, CO
Dennis Deniro, Ohio EPA, DEFA, CO

7010 1060 0000 0089 5212

CERTIFIED MAIL RECEIPT
(Domestic Mail Only; No Insurance Coverage Included)

For delivery information, visit our website at www.usps.com

Postage	\$	Postmark Here
Certified Fee		
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
Total Postage & Fees	\$	

Sent To

Street, Apt. No.,
or PO Box No.

City, State, ZIP+4