





**Environmental  
Protection Agency**

John R. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott J. Nally, **Director**

Re: Wyandot County  
Angle Back Just One More Time  
TNC Water System  
PWS ID # OH8836612

July 13, 2012

Mr. Jerry Pahl  
Angle Back Just One More Time  
20164 State Route 67  
Upper Sandusky, Ohio 43351

Dear Mr. Pahl:

This letter will confirm removal of the water use advisory required in our letter dated July 12, 2012. This is based on one set of four total coliform negative (safe) samples collected on July 9, 2012, and received by our office at the end of the day July 11, 2012.

Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402, by July 27, 2012.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of July 2012.

Yours truly,

Chris Riddle  
Division of Drinking and Ground Waters

//lr

pc: Wyandot County Health Department  
DDAGW, NWDO

