




**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



July 10, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Mark Anthony
15111 SR 664 South
Logan, OH 43138

Hocking County
Valleyview Estates MHP
COMMUNITY PWS
PWS ID: OH3700312

Dear Public Water System Owner:

The Public Water System serving Valleyview Estates MHP is in violation of the Ohio Administrative Code (OAC) for:

Failure to respond in Writing within 30 days:

Valleyview Estates MHP has not complied with requirements issued during this Agency's last survey performed on March 30, 2012, in violation of rule 3745-81-60 of the Ohio Administrative Code. You were notified in the sanitary survey letter dated April 5, 2012, to respond, in writing, no later than 30 days from the date of the letter.

Failure to respond in Writing within 15 days:

Valleyview Estates MHP has not complied with the 15 day extension letter sent on June 7, 2012. The letter asked you to respond to the sanitary survey requirements as noted below:

1. An updated contingency plan must be compiled. Mr. Bennett was provided with a template for the required plan. The plan should include:
 - Names and contact information including phone numbers and email addresses
 - A list and contact information of suppliers
 - Approved laboratory list and contact information for bacteria and other parameters that might be required during an emergency
 - Public notice procedure
2. Bacteria samples for this system are being collected from an inappropriate tap. The location of the sampling is correct (post treatment) but the "sink" being utilized has a screw nozzle which could be connected to a hose. Please replace this nozzle with an AWWA approved sampling tap.

3. At the time of this inspection, the flow meter for the Park could not be read due to corrosion and other residue. It was noted that this meter was scheduled to be replaced within the next few weeks. Please submit information on the new meter that is being installed and the date in which it was put into operation.
4. The operator noted that the park was using approximately 300 gpd per trailer (8,100 gpd). However, the results submitted on the monthly operating reports indicate an average usage of 4,000 gpd. Please ensure that adequate flow results are reported once the new meter is placed into operation.

If you have any questions please call me at 740-380-5229.

Sincerely,



Russell Flagg

RF/cb

cc: C.O. - DDAGW / OFAS / Dave Riley
cc: Hocking County Health Dept.
cc: Jim Bennett, Operator (with enclosures)
20355 Carroll Rd
Rockbridge, OH 43149